



October 5, 2004

FREEDOM PLASTICS, INC.
GART WOLFE

PO BOX 1488
JANESVILLE WI 53547-1488

Re: Description: PIPES, PVC
Manufacturer: FREEDOM PLASTICS, INC.
Product Name: ASTM D-33034
Model Number(s): SDR35 4" & 6"
Product File No: 20040493

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.30 (2) & (3) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of October 2009.

This alternate approval is contingent upon compliance with the following stipulation(s):

- The pipe must have 2 rows, and only 2 rows, of perforations parallel to the axis of the pipe and 120 degrees, plus or minus 5 degrees apart. The perforations must be located at the nominal 4 and 8 o'clock positions when the pipe is installed.
- This product may only be installed for perforated effluent distribution piping for nonpressurized soil treatment or dispersal component.
- This product must be labeled with pipe size, FREEDOM FPI 12454-B SDR 35 TYPE PSM PVC SEWER PIPE ASTM D-3034.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wi.gov

19970043